

Adirondack Environmental Services, Inc

CASE NARRATIVE

Duanesburg Central School

Date: 04-Jan-21

Water Analysis

Lab WorkOrder: 201209053

High School & Elementary School

The sampling was performed in accordance with the AES field sampling procedures and/or the client specified sampling procedures. Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-001**Collection Date:** 12/9/2020**Client Sample ID:** HS-2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 10:32:09 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-002**Collection Date:** 12/9/2020**Client Sample ID:** HS-3**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 10:50:52 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-003**Collection Date:** 12/9/2020**Client Sample ID:** HS-4**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 10:54:37 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-004**Collection Date:** 12/9/2020**Client Sample ID:** HS-5**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 10:58:23 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-005**Collection Date:** 12/9/2020**Client Sample ID:** HS-6**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 11:02:09 PM
------	----	-----	--	------	---	------------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-006**Collection Date:** 12/9/2020**Client Sample ID:** HS-7**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 11:05:54 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-007**Collection Date:** 12/9/2020**Client Sample ID:** HS-13**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 11:09:40 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-008**Collection Date:** 12/9/2020**Client Sample ID:** HS-14**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 11:13:26 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-009**Collection Date:** 12/9/2020**Client Sample ID:** HS-26**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 11:17:12 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-010**Collection Date:** 12/9/2020**Client Sample ID:** HS-27**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 11:20:57 PM
------	----	-----	--	------	---	------------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-011**Collection Date:** 12/9/2020**Client Sample ID:** HS-28**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 11:32:10 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-012**Collection Date:** 12/9/2020**Client Sample ID:** HS-29**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 11:43:27 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-013**Collection Date:** 12/9/2020**Client Sample ID:** HS-29A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 11:47:13 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-014**Collection Date:** 12/9/2020**Client Sample ID:** HS-30**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	3.0	1.0		µg/L	1	12/29/2020 11:50:58 PM
------	-----	-----	--	------	---	------------------------

Lab SampleID: 201209053-015**Collection Date:** 12/9/2020**Client Sample ID:** HS-31**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 11:54:44 PM
------	----	-----	--	------	---	------------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-016**Collection Date:** 12/9/2020**Client Sample ID:** HS-32**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	2.8	1.0		µg/L	1	12/29/2020 11:58:31 PM
------	-----	-----	--	------	---	------------------------

Lab SampleID: 201209053-017**Collection Date:** 12/9/2020**Client Sample ID:** HS-33**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:02:17 AM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-018**Collection Date:** 12/9/2020**Client Sample ID:** HS-34**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	1.3	1.0		µg/L	1	12/30/2020 12:06:03 AM
------	-----	-----	--	------	---	------------------------

Lab SampleID: 201209053-019**Collection Date:** 12/9/2020**Client Sample ID:** HS-35**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:17:15 AM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-020**Collection Date:** 12/9/2020**Client Sample ID:** HS-36**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:21:01 AM
------	----	-----	--	------	---	------------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-021**Collection Date:** 12/9/2020**Client Sample ID:** HS-37**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	10.9	1.0		µg/L	1	12/30/2020 12:32:19 AM
------	------	-----	--	------	---	------------------------

Lab SampleID: 201209053-022**Collection Date:** 12/9/2020**Client Sample ID:** HS-38**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:43:37 AM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-023**Collection Date:** 12/9/2020**Client Sample ID:** HS-46**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:47:24 AM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-024**Collection Date:** 12/9/2020**Client Sample ID:** HS-47**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	2.1	1.0		µg/L	1	12/30/2020 12:51:11 AM
------	-----	-----	--	------	---	------------------------

Lab SampleID: 201209053-025**Collection Date:** 12/9/2020**Client Sample ID:** HS-48**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:02:24 AM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-026**Collection Date:** 12/9/2020**Client Sample ID:** HS-49**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:06:10 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-027**Collection Date:** 12/9/2020**Client Sample ID:** HS-50**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:09:57 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-028**Collection Date:** 12/9/2020**Client Sample ID:** HS-51**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:13:43 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-029**Collection Date:** 12/9/2020**Client Sample ID:** HS-52**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:17:30 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-030**Collection Date:** 12/9/2020**Client Sample ID:** HS-53**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:21:16 AM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-031**Collection Date:** 12/9/2020**Client Sample ID:** HS-54**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	3.6	1.0		µg/L	1	12/30/2020 1:25:03 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-032**Collection Date:** 12/9/2020**Client Sample ID:** HS-55**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	3.8	1.0		µg/L	1	12/30/2020 1:36:23 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-033**Collection Date:** 12/9/2020**Client Sample ID:** HS-56**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 11:07:17 AM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-034**Collection Date:** 12/9/2020**Client Sample ID:** HS-57**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 11:11:04 AM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-035**Collection Date:** 12/9/2020**Client Sample ID:** HS-58**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 11:14:50 AM
------	----	-----	--	------	---	------------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-036**Collection Date:** 12/9/2020**Client Sample ID:** HS-59**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 11:18:37 AM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-037**Collection Date:** 12/9/2020**Client Sample ID:** HS-60**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 11:22:24 AM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-038**Collection Date:** 12/9/2020**Client Sample ID:** HS-62**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	3.4	1.0		µg/L	1	12/30/2020 11:26:10 AM
------	-----	-----	--	------	---	------------------------

Lab SampleID: 201209053-039**Collection Date:** 12/9/2020**Client Sample ID:** HS-63A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	2.5	1.0		µg/L	1	12/30/2020 11:29:57 AM
------	-----	-----	--	------	---	------------------------

Lab SampleID: 201209053-040**Collection Date:** 12/9/2020**Client Sample ID:** HS-63B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	2.5	1.0		µg/L	1	12/30/2020 11:33:44 AM
------	-----	-----	--	------	---	------------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-041**Collection Date:** 12/9/2020**Client Sample ID:** HS-64**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 11:52:32 AM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-042**Collection Date:** 12/9/2020**Client Sample ID:** HS-65**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:03:53 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-043**Collection Date:** 12/9/2020**Client Sample ID:** HS-66**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	1.4	1.0		µg/L	1	12/30/2020 12:07:40 PM
------	-----	-----	--	------	---	------------------------

Lab SampleID: 201209053-044**Collection Date:** 12/9/2020**Client Sample ID:** HS-67**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:11:27 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-045**Collection Date:** 12/9/2020**Client Sample ID:** HS-68**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:15:13 PM
------	----	-----	--	------	---	------------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-046**Collection Date:** 12/9/2020**Client Sample ID:** HS-77**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:19:00 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-047**Collection Date:** 12/9/2020**Client Sample ID:** HS-78**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:22:47 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-048**Collection Date:** 12/9/2020**Client Sample ID:** HS-79**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:26:34 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-049**Collection Date:** 12/9/2020**Client Sample ID:** HS-80**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:37:48 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-050**Collection Date:** 12/9/2020**Client Sample ID:** HS-81**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	7.1	1.0		µg/L	1	12/30/2020 12:41:35 PM
------	-----	-----	--	------	---	------------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-051**Collection Date:** 12/9/2020**Client Sample ID:** HS-101**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	184	1.0	X	µg/L	1	12/30/2020 12:45:21 PM
------	-----	-----	---	------	---	------------------------

Lab SampleID: 201209053-052**Collection Date:** 12/9/2020**Client Sample ID:** HS-104**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 12:49:08 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-053**Collection Date:** 12/9/2020**Client Sample ID:** HS-105**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:00:30 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-054**Collection Date:** 12/9/2020**Client Sample ID:** HS-106**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:04:17 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-055**Collection Date:** 12/9/2020**Client Sample ID:** HS-107**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:08:05 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-056**Collection Date:** 12/9/2020**Client Sample ID:** HS-108**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:11:52 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-057**Collection Date:** 12/9/2020**Client Sample ID:** HS-109**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:23:05 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-058**Collection Date:** 12/9/2020**Client Sample ID:** HS-110**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:26:53 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-059**Collection Date:** 12/9/2020**Client Sample ID:** HS-111**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:30:40 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-060**Collection Date:** 12/9/2020**Client Sample ID:** HS-112**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:34:27 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-061**Collection Date:** 12/9/2020**Client Sample ID:** HS-113**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:45:49 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-062**Collection Date:** 12/9/2020**Client Sample ID:** HS-114A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 1:57:11 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-063**Collection Date:** 12/9/2020**Client Sample ID:** HS-114B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 2:08:25 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-064**Collection Date:** 12/9/2020**Client Sample ID:** HS-115**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 2:12:13 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-065**Collection Date:** 12/9/2020**Client Sample ID:** HS-116**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 2:16:00 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-066**Collection Date:** 12/9/2020**Client Sample ID:** HS-117**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 2:19:48 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-067**Collection Date:** 12/9/2020**Client Sample ID:** HS-119**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	4.9	1.0		µg/L	1	12/30/2020 2:23:35 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-068**Collection Date:** 12/9/2020**Client Sample ID:** HS-120**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	2.0	1.0		µg/L	1	12/30/2020 2:27:23 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-069**Collection Date:** 12/9/2020**Client Sample ID:** HS-121A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 2:31:10 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-070**Collection Date:** 12/9/2020**Client Sample ID:** HS-121B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 2:34:58 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-071**Collection Date:** 12/9/2020**Client Sample ID:** HS-122**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 2:38:41 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-072**Collection Date:** 12/9/2020**Client Sample ID:** HS-124**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	ND	1.0		µg/L	1	12/30/2020 2:57:18 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-073**Collection Date:** 12/9/2020**Client Sample ID:** HS-126**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	5.2	1.0		µg/L	1	12/30/2020 3:01:02 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-074**Collection Date:** 12/9/2020**Client Sample ID:** HS-200**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/9/2020)

Lead	4.1	1.0		µg/L	1	12/30/2020 3:04:46 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-075**Collection Date:** 12/15/2020**Client Sample ID:** ES-1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	2.9	1.0		µg/L	1	12/28/2020 5:37:22 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-076**Collection Date:** 12/15/2020**Client Sample ID:** ES-2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	8.2	1.0		µg/L	1	12/28/2020 5:48:32 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-077**Collection Date:** 12/15/2020**Client Sample ID:** ES-3**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	3.4	1.0		µg/L	1	12/28/2020 5:52:16 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-078**Collection Date:** 12/15/2020**Client Sample ID:** ES-5**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	6.6	1.0		µg/L	1	12/28/2020 5:55:59 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-079**Collection Date:** 12/15/2020**Client Sample ID:** ES-6**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 5:59:43 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-080**Collection Date:** 12/15/2020**Client Sample ID:** ES-8**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	9.1	1.0		µg/L	1	12/28/2020 6:03:27 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-081**Collection Date:** 12/15/2020**Client Sample ID:** ES-9**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	4.1	1.0		µg/L	1	12/28/2020 6:14:38 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-082**Collection Date:** 12/15/2020**Client Sample ID:** ES-10**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	6.6	1.0		µg/L	1	12/28/2020 6:18:22 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-083**Collection Date:** 12/15/2020**Client Sample ID:** ES-13**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 6:22:07 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-084**Collection Date:** 12/15/2020**Client Sample ID:** ES-14**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	8.3	1.0		µg/L	1	12/28/2020 6:25:51 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-085**Collection Date:** 12/15/2020**Client Sample ID:** ES-15**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 6:29:35 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-086**Collection Date:** 12/15/2020**Client Sample ID:** ES-16A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 6:40:46 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-087**Collection Date:** 12/15/2020**Client Sample ID:** ES-16B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 6:44:29 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-088**Collection Date:** 12/15/2020**Client Sample ID:** ES-17**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 6:48:13 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-089**Collection Date:** 12/15/2020**Client Sample ID:** ES-18**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 6:59:23 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-090**Collection Date:** 12/15/2020**Client Sample ID:** ES-19**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 7:03:07 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-091**Collection Date:** 12/15/2020**Client Sample ID:** ES-20**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 7:06:52 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-092**Collection Date:** 12/15/2020**Client Sample ID:** ES-21**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 7:10:36 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-093**Collection Date:** 12/15/2020**Client Sample ID:** ES-22**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 7:14:21 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-094**Collection Date:** 12/15/2020**Client Sample ID:** ES-23**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 7:18:05 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-095**Collection Date:** 12/15/2020**Client Sample ID:** ES-24**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 7:36:43 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-096**Collection Date:** 12/15/2020**Client Sample ID:** ES-25**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 7:47:55 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-097**Collection Date:** 12/15/2020**Client Sample ID:** ES-26**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 7:51:39 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-098**Collection Date:** 12/15/2020**Client Sample ID:** ES-27**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/28/2020 7:55:23 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-099**Collection Date:** 12/15/2020**Client Sample ID:** ES-28**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	1.5	1.0		µg/L	1	12/28/2020 7:59:08 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-100**Collection Date:** 12/15/2020**Client Sample ID:** ES-29**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	1.0	1.0		µg/L	1	12/28/2020 8:02:52 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-101**Collection Date:** 12/15/2020**Client Sample ID:** ES-30**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	6.6	1.0	S+	µg/L	1	12/29/2020 6:28:52 PM
------	-----	-----	----	------	---	-----------------------

Lab SampleID: 201209053-102**Collection Date:** 12/15/2020**Client Sample ID:** ES-31**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	1.3	1.0	S+	µg/L	1	12/29/2020 6:32:36 PM
------	-----	-----	----	------	---	-----------------------

Lab SampleID: 201209053-103**Collection Date:** 12/15/2020**Client Sample ID:** ES-32**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 6:36:20 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-104**Collection Date:** 12/15/2020**Client Sample ID:** ES-33**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	1.8	1.0	S+	µg/L	1	12/29/2020 6:40:04 PM
------	-----	-----	----	------	---	-----------------------

Lab SampleID: 201209053-105**Collection Date:** 12/15/2020**Client Sample ID:** ES-34**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	2.0	1.0	S+	µg/L	1	12/29/2020 6:43:49 PM
------	-----	-----	----	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-106**Collection Date:** 12/15/2020**Client Sample ID:** ES-38**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	4.8	1.0	S+	µg/L	1	12/29/2020 6:55:01 PM
------	-----	-----	----	------	---	-----------------------

Lab SampleID: 201209053-107**Collection Date:** 12/15/2020**Client Sample ID:** ES-39**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 6:58:45 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-108**Collection Date:** 12/15/2020**Client Sample ID:** ES-40**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	5.1	1.0	S+	µg/L	1	12/29/2020 7:02:29 PM
------	-----	-----	----	------	---	-----------------------

Lab SampleID: 201209053-109**Collection Date:** 12/15/2020**Client Sample ID:** ES-41**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	7.7	1.0	S+	µg/L	1	12/29/2020 7:13:40 PM
------	-----	-----	----	------	---	-----------------------

Lab SampleID: 201209053-110**Collection Date:** 12/15/2020**Client Sample ID:** ES-42**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	5.9	1.0	S+	µg/L	1	12/29/2020 7:17:25 PM
------	-----	-----	----	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-111**Collection Date:** 12/15/2020**Client Sample ID:** ES-43**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	3.7	1.0	S+	µg/L	1	12/29/2020 7:21:10 PM
------	-----	-----	----	------	---	-----------------------

Lab SampleID: 201209053-112**Collection Date:** 12/15/2020**Client Sample ID:** ES-44**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	3.3	1.0	S+	µg/L	1	12/29/2020 7:24:54 PM
------	-----	-----	----	------	---	-----------------------

Lab SampleID: 201209053-113**Collection Date:** 12/15/2020**Client Sample ID:** ES-45**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	3.2	1.0	S+	µg/L	1	12/29/2020 7:28:38 PM
------	-----	-----	----	------	---	-----------------------

Lab SampleID: 201209053-114**Collection Date:** 12/15/2020**Client Sample ID:** ES-46**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	3.8	1.0	S+	µg/L	1	12/29/2020 7:32:23 PM
------	-----	-----	----	------	---	-----------------------

Lab SampleID: 201209053-115**Collection Date:** 12/15/2020**Client Sample ID:** ES-47**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	1.7	1.0		µg/L	1	12/29/2020 7:43:36 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-116**Collection Date:** 12/15/2020**Client Sample ID:** ES-48**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	1.7	1.0		µg/L	1	12/29/2020 8:02:16 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-117**Collection Date:** 12/15/2020**Client Sample ID:** ES-50**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	1.3	1.0		µg/L	1	12/29/2020 8:06:00 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-118**Collection Date:** 12/15/2020**Client Sample ID:** ES-51**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	1.2	1.0		µg/L	1	12/29/2020 8:09:45 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-119**Collection Date:** 12/15/2020**Client Sample ID:** ES-52**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 8:13:30 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-120**Collection Date:** 12/15/2020**Client Sample ID:** ES-53**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 8:17:15 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-121**Collection Date:** 12/15/2020**Client Sample ID:** ES-54**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	7.2	1.0		µg/L	1	12/29/2020 8:21:00 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-122**Collection Date:** 12/15/2020**Client Sample ID:** ES-56**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	5.6	1.0		µg/L	1	12/29/2020 8:24:45 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-123**Collection Date:** 12/15/2020**Client Sample ID:** ES-57**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	6.5	1.0		µg/L	1	12/29/2020 8:28:30 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-124**Collection Date:** 12/15/2020**Client Sample ID:** ES-58**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	8.2	1.0		µg/L	1	12/29/2020 8:39:41 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-125**Collection Date:** 12/15/2020**Client Sample ID:** ES-59**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	6.2	1.0		µg/L	1	12/29/2020 8:43:26 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-126**Collection Date:** 12/15/2020**Client Sample ID:** ES-60**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 8:54:41 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-127**Collection Date:** 12/15/2020**Client Sample ID:** ES-61**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 8:58:26 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-128**Collection Date:** 12/15/2020**Client Sample ID:** ES-62**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 9:02:10 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-129**Collection Date:** 12/15/2020**Client Sample ID:** ES-63**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	1.0	1.0		µg/L	1	12/29/2020 9:05:56 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-130**Collection Date:** 12/15/2020**Client Sample ID:** ES-64**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 9:17:07 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053**PO#:****Lab SampleID:** 201209053-131**Collection Date:** 12/15/2020**Client Sample ID:** ES-65**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	1.2	1.0		µg/L	1	12/29/2020 9:20:52 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-132**Collection Date:** 12/15/2020**Client Sample ID:** ES-66**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 9:24:38 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-133**Collection Date:** 12/15/2020**Client Sample ID:** ES-67**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 9:28:23 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-134**Collection Date:** 12/15/2020**Client Sample ID:** ES-69**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 9:32:08 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201209053-135**Collection Date:** 12/15/2020**Client Sample ID:** ES-70**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 9:43:23 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-136**Collection Date:** 12/15/2020**Client Sample ID:** ES-71**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 10:02:06 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-137**Collection Date:** 12/15/2020**Client Sample ID:** ES-72**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 10:05:51 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-138**Collection Date:** 12/15/2020**Client Sample ID:** ES-73**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 10:09:36 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-139**Collection Date:** 12/15/2020**Client Sample ID:** ES-74**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 10:13:22 PM
------	----	-----	--	------	---	------------------------

Lab SampleID: 201209053-140**Collection Date:** 12/15/2020**Client Sample ID:** ES-75**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 12/15/2020)

Lead	ND	1.0		µg/L	1	12/29/2020 10:17:07 PM
------	----	-----	--	------	---	------------------------

Adirondack Environmental Services, Inc**Date:** 04-Jan-21

CLIENT: Duaneburg Central School
Project: Water Analysis
High School & Elementary School

LabWork Order: 201209053
PO#:

Lab SampleID: 201209053-141**Collection Date:** 12/15/2020**Client Sample ID:** ES-76**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4**Analyst:** SM

(Prep: - 12/15/2020)

Lead	21.7	1.0	X	µg/L	1	12/29/2020 10:20:53 PM
------	------	-----	---	------	---	------------------------



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

201209053

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Duanesburg CSD		Address:							
Send Report to:		Project Name (Location): Duanesburg High School				Samplers Name: Michael Wilsey			
Client Phone #:		Client PO #:				Samplers Signature:			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	001 HS-2	12/09/20		PW		X	1	0	Lead
002	002 HS-3			PW		X	1	0	Lead
003	003 HS-4			PW		X	1	0	Lead
004	004 HS-5			PW		X	1	0	Lead
005	005 HS-6			PW		X	1	0	Lead
006	006 HS-7			PW		X	1	0	Lead
007	007 HS-13			PW		X	1	0	Lead
008	008 HS-14			PW		X	1	0	Lead
009	009 HS-26			PW		X	1	0	Lead
010	010 HS-27			PW		X	1	0	Lead
011	011 HS-28			PW		X	1	0	Lead
012	012 HS-29			PW		X	1	0	Lead
013	013 HS-29A			PW		X	1	0	Lead
014	014 HS-30			PW		X	1	0	Lead
015	015 HS-31			PW		X	1	0	Lead
016	016 HS-32			PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:			
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard					
NOTE: Samples received after 3:30pm are considered next business day.					
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received for Laboratory by:		Date	Time
		12-9-20		3:10PM	

Sample Temperature Ambient		Properly Preserved: Y / N		Received Within Holding Times: Y / N	
Notes: Ice preservation not required		0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃		5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/Nr 9=NaOH p 10=Other_	
Bottles AES: Y / N					



201209053



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

201209053

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Duanesburg CSD		Address:							
Send Report to:		Project Name (Location): Duanesburg High School				Samplers Name: <i>Michael Wilson</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
017	017 HS-33	12/09/20		PW		X	1	0	Lead
018	018 HS-34			PW		X	1	0	Lead
019	019 HS-35			PW		X	1	0	Lead
020	020 HS-36			PW		X	1	0	Lead
021	021 HS-37			PW		X	1	0	Lead
022	022 HS-38			PW		X	1	0	Lead
023	023 HS-46			PW		X	1	0	Lead
024	024 HS-47			PW		X	1	0	Lead
025	025 HS-48			PW		X	1	0	Lead
026	026 HS-49			PW		X	1	0	Lead
027	027 HS-50			PW		X	1	0	Lead
028	028 HS-51			PW		X	1	0	Lead
029	029 HS-52			PW		X	1	0	Lead
030	030 HS-53			PW		X	1	0	Lead
031	031 HS-54			PW		X	1	0	Lead
032	032 HS-55			PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:			
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day <u>Standard</u>					
NOTE: Samples received after 3:30pm are considered next business day.					
PLEASE FILL ALL PINK SHADED AREAS					
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received for Laboratory by:		Date	Time
		<i>[Signature]</i>		12-9-20	3:16PM
Sample Temperature Ambient Notes: Ice preservation not required		Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other		Received Within Holding Times: Y N Notes:	
Bottles AES: <u>Y</u> / N					



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

201209053

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Duanesburg CSD		Address:							
Send Report to:		Project Name (Location): Duanesburg High School				Samplers Name: <i>Michael Wilsey</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
033	033 HS-56	12/09/20		PW		X	1	0	Lead
034	034 HS-57			PW		X	1	0	Lead
035	035 HS-58			PW		X	1	0	Lead
036	036 HS-59			PW		X	1	0	Lead
037	037 HS-60			PW		X	1	0	Lead
038	038 HS-62			PW		X	1	0	Lead
039	039 HS-63A			PW		X	1	0	Lead
040	040 HS-63B			PW		X	1	0	Lead
041	041 HS-64			PW		X	1	0	Lead
042	042 HS-65			PW		X	1	0	Lead
043	043 HS-66			PW		X	1	0	Lead
044	044 HS-67			PW		X	1	0	Lead
045	045 HS-68			PW		X	1	0	Lead
046	046 HS-77			PW		X	1	0	Lead
047	047 HS-78			PW		X	1	0	Lead
048	048 HS-79			PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other: _____		Special Instructions/Remarks:		
Turnaround Time Requested: ④ 1 Day ④ 2 Day ③ Day 5 Day <u>Standard</u>				
NOTE: Samples received after 3:30pm are considered next business day.				
Relinquished by: (Signature) <i>[Signature]</i>		Received by: (Signature)	Date	Time
Relinquished by: (Signature) <i>[Signature]</i>		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received for Laboratory by: <i>[Signature]</i>	Date 12-9-20	Time 3:10PM

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

201209053

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Duanesburg CSD		Address:							
Send Report to:		Project Name (Location): Duanesburg High School				Samplers Name: <i>Michael Wilsey</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
049	049 HS-80	12/09/20		PW		X	1	0	Lead
050	050 HS-81			PW		X	1	0	Lead
051	051 HS-101			PW		X	1	0	Lead
052	052 HS-104			PW		X	1	0	Lead
053	053 HS-105			PW		X	1	0	Lead
054	054 HS-106			PW		X	1	0	Lead
055	055 HS-107			PW		X	1	0	Lead
056	056 HS-108			PW		X	1	0	Lead
057	057 HS-109			PW		X	1	0	Lead
058	058 HS-110			PW		X	1	0	Lead
059	059 HS-111			PW		X	1	0	Lead
060	060 HS-112			PW		X	1	0	Lead
061	061 HS-113			PW		X	1	0	Lead
062	062 HS-114A			PW		X	1	0	Lead
063	063 HS-114B			PW		X	1	0	Lead
064	064 HS-115			PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other: _____		Special Instructions/Remarks:		
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day <u>Standard</u>				
NOTE: Samples received after 3:30pm are considered next business day.				
Relinquished by: (Signature) <i>[Signature]</i>		Received by: (Signature)	Date	Time
Relinquished by: (Signature) <i>[Signature]</i>		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received for Laboratory by: <i>[Signature]</i>	Date 12-9-20	Time 3:10PM

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

201209053

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Duanesburg CSD		Address:							
Send Report to:		Project Name (Location): Duanesburg High School				Samplers Name: Michael Wilsey			
Client Phone #:		Client PO #:				Samplers Signature:			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
065	065 HS-116	12/09/20		PW		X	1	0	Lead
066	066 HS-117			PW		X	1	0	Lead
067	067 HS-119			PW		X	1	0	Lead
068	068 HS-120			PW		X	1	0	Lead
069	069 HS-121A			PW		X	1	0	Lead
070	070 HS-121B			PW		X	1	0	Lead
071	071 HS-122			PW		X	1	0	Lead
072	072 HS-124			PW		X	1	0	Lead
073	073 HS-126			PW		X	1	0	Lead
074	074 HS-200			PW		X	1	0	Lead
075				PW		X	1	0	Lead
	076			PW		X	1	0	Lead
	077			PW		X	1	0	Lead
	078			PW		X	1	0	Lead
	079			PW		X	1	0	Lead
	080			PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____		Special Instructions/Remarks:		
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day <u>Standard</u>				
NOTE: Samples received after 3:30pm are considered next business day.				
Relinquished by: (Signature) 		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received for Laboratory by: 	Date 12-9-20	Time 3:10 PM

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		

314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY REC

AES Work Order#:

201209053

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Duaneburg CSD		Address:							
Send Report to:		Project Name (Location): Elementary School				Samplers Name: Michael Wilks			
Client Phone #:		Client PO #:				Samplers Signature:			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
075	ES- 1	12/15/20		PW		X	1	0	Lead
076	ES- 2			PW		X	1	0	Lead
077	ES- 3			PW		X	1	0	Lead
078	ES- 5			PW		X	1	0	Lead
079	ES- 6			PW		X	1	0	Lead
080	ES- 8			PW		X	1	0	Lead
081	ES- 9			PW		X	1	0	Lead
082	ES- 10			PW		X	1	0	Lead
083	ES- 13			PW		X	1	0	Lead
084	ES- 14			PW		X	1	0	Lead
085	ES- 15			PW		X	1	0	Lead
086	ES- 14A			PW		X	1	0	Lead
087	ES- 14B			PW		X	1	0	Lead
088	ES- 17			PW		X	1	0	Lead
089	ES- 18			PW		X	1	0	Lead
090	ES- 19			PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:		Special Instructions/Remarks: 1/5	
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day <u>Standard</u> NOTE: Samples received after 3:30pm are considered next business day		ADD TO WORK ORDER 201209053	
Relinquished by: (Signature)		Received by: (Signature)	
Relinquished by: (Signature)		Received by: (Signature)	
Relinquished by: (Signature)		Received for Laboratory by:	
Sample Temperature Ambient		Properly Preserved: <u>Y</u> / N	
Notes: Ice preservation not required		Received Within Hold <u>Y</u> / N	
		Notes:	

314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY REC


AES Work Order#:


201209053

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Duanesburg CSD		Address:							
Send Report to:		Project Name (Location): Elementary School			Samplers Name: Michael Wilsy				
Client Phone #:		Client PO #:			Samplers Signature: 				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
091	ES- 20	12/15/20		PW		X	1	0	Lead
092	ES- 21			PW		X	1	0	Lead
093	ES- 22			PW		X	1	0	Lead
094	ES- 23			PW		X	1	0	Lead
095	ES- 24			PW		X	1	0	Lead
096	ES- 25			PW		X	1	0	Lead
097	ES- 26			PW		X	1	0	Lead
098	ES- 27			PW		X	1	0	Lead
099	ES- 28			PW		X	1	0	Lead
100	ES- 29			PW		X	1	0	Lead
101	ES- 30			PW		X	1	0	Lead
102	ES- 31			PW		X	1	0	Lead
103	ES- 32			PW		X	1	0	Lead
104	ES- 33			PW		X	1	0	Lead
105	ES- 34			PW		X	1	0	Lead
106	ES- 38			PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____		Special Instructions/Remarks: 2/5
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day <u>Standard</u> NOTE: Samples received after 3:30pm are considered next business day.		
Relinquished by: (Signature)		Received by: (Signature)
Relinquished by: (Signature)		Received by: (Signature)
Relinquished by: (Signature)		Received for Laboratory by: 
Sample Temperature Ambient 		Received Within Hold <u>Y</u> / N
Notes: Ice preservation not required		Notes:

0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2	5=NH ₄ Cl 6=Ascorbic Acid 7=FAS
--	--

314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY REC

AES Work Order#:

201209053

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Duanesburg CSD		Address:							
Send Report to:		Project Name (Location): Elementary School		Samplers Name: Michael Wilkey					
Client Phone #:		Client PO #:		Samplers Signature:					
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
107	ES- 39	12/15/20		PW		X	1	0	Lead
108	ES- 40			PW		X	1	0	Lead
109	ES- 41			PW		X	1	0	Lead
110	ES- 42			PW		X	1	0	Lead
111	ES- 43			PW		X	1	0	Lead
112	ES- 44			PW		X	1	0	Lead
113	ES- 45			PW		X	1	0	Lead
114	ES- 46			PW		X	1	0	Lead
115	ES- 47			PW		X	1	0	Lead
116	ES- 48			PW		X	1	0	Lead
117	ES- 50			PW		X	1	0	Lead
118	ES- 51			PW		X	1	0	Lead
119	ES- 52			PW		X	1	0	Lead
120	ES- 53			PW		X	1	0	Lead
121	ES- 54			PW		X	1	0	Lead
122	ES- 56			PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>(AES)</u> Other:		Special Instructions/Remarks: 3/5		
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day <u>Standard</u> NOTE: Samples received after 3:30pm are considered next business day.				
Relinquished by: (Signature)		Received by: (Signature)		Date
Relinquished by: (Signature)		Received by: (Signature)		Date
Relinquished by: (Signature)		Received for Laboratory by:		Date
Sample Temperature Ambient		Properly Preserved: <u>Y</u> / N		Received Within Hold <u>Y</u> / N
Notes: Ice preservation not required		0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS		Notes:

314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY REC'D

AES Work Order#:

201209053

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Duanesburg CSD		Address:							
Send Report to:		Project Name (Location): Elementary School				Samplers Name: Michael Wilsey			
Client Phone #:		Client PO #:				Samplers Signature:			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
123	ES- 57	12/15/20		PW		X	1	0	Lead
124	ES- 58			PW		X	1	0	Lead
125	ES- 59			PW		X	1	0	Lead
126	ES- 60			PW		X	1	0	Lead
127	ES- 61			PW		X	1	0	Lead
128	ES- 62			PW		X	1	0	Lead
129	ES- 63			PW		X	1	0	Lead
130	ES- 64			PW		X	1	0	Lead
131	ES- 65			PW		X	1	0	Lead
132	ES- 66			PW		X	1	0	Lead
133	ES- 67			PW		X	1	0	Lead
134	ES- 68			PW		X	1	0	Lead
135	ES- 70			PW		X	1	0	Lead
136	ES- 71			PW		X	1	0	Lead
137	ES- 72			PW		X	1	0	Lead
138	ES- 73			PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____				Special Instructions/Remarks: 4/5					
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day <u>Standard</u> NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature)				Received by: (Signature)				Date	
Relinquished by: (Signature)				Received by: (Signature)				Date	
Relinquished by: (Signature)				Received for Laboratory by:				Date	
Sample Temperature Ambient				Properly Preserved: <u>Y</u> / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS				Received Within Hold <u>Y</u> / N	
Notes: Ice preservation not required				Notes:					

314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY REC'D

AES Work Order#:

201209053

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Duanesburg CSD		Address:	
Send Report to:		Project Name (Location): Elementary School	
Client Phone #:		Samplers Name: <i>Michael Willey</i>	
Client Email:		Samplers Signature: <i>[Signature]</i>	

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
139	ES- 74	12/15/20		PW		X	1	0	Lead
140	ES- 75	↓		PW		X	1	0	Lead
141	ES- 76	↓		PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead
	ES-			PW		X	1	0	Lead

Shipment Arrived Via:
FedEx UPS Client AES Other: _____

Special Instructions/Remarks: *5/5*

Turnaround Time Requested:
④ 1 Day ④ 2 Day 3 Day 5 Day Standard
NOTE: Samples received after 3:30pm are considered next business day.

PLEASE FILL ALL PINK SHADED AREAS

Relinquished by: (Signature)	Received by: (Signature)	Date
Relinquished by: (Signature)	Received by: (Signature)	Date
Relinquished by: (Signature)	Received for Laboratory by:	Date

Sample Temperature Ambient	Properly Preserved: <u>Y</u> / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS	Received Within Hold <u>Y</u> / N Notes:
-------------------------------	--	--



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.